

ROWLAND UNIFIED SCHOOL DISTRICT
1830 S. NOGALES STREET
ROWLAND HEIGHTS, CA 91748



ADDENDUM 2

Bid No. 2019/20: (R18) – Rowland High School Gym Roof Replacement Project

Bid No. 2019/20: (R19) – Nogales High School Gym Roof Replacement Project

MAY 27, 2020

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

Specifications/Clarifications:

1. At the lower Roof sections at both Rowland HS & Nogales HS that are to receive PVC KEE Fleeceback Membrane, please include the installation of 1" Paratherm CG adhered with insulation adhesive. Membrane is to be attached to insulation with Membrane Adhesive. 1" treated wood nailers will be required at all metal edge details to accommodate for insulation and metal transition. Temporary Roof Membrane to remain in system and installed per specification.

Rosana McLeod

Director of Purchasing