



ROWLAND UNIFIED SCHOOL DISTRICT
1830 S. NOGALES STREET
ROWLAND HEIGHTS, CA 91748

ADDENDUM 3
Kitchen Modernization Project
Blandford Elementary School
Bid No. RFP 2024-25 (R1)

NOVEMBER 5, 2024

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents, and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

Specifications/Clarifications:

Request for Information are due no later than November 8, 2024 by 3:30 p.m. via email to rmcleod@rowlandschools.org

Prequalification forms due date has been extended from November 5, 2024, to November 7, 2024, no later than 2:00 p.m. at the Rowland Unified School District Purchasing Office, 1830 S. Nogales Street, Rowland Heights, CA 91748. Prequalification forms may not be emailed. You are to hand them in, in person or Fed Ex/UPS at your on risk.

- 1. Question:** (N) signs are shown on drawings, but signage specs are not included in spec book.
Answer: New signs shall be provided per details 18 & 19 on sheet A-5.1. See attached specification section "10 14 00 Signage" for additional information.
- 2. Question:** RFI #2- please Verify/clarify the Network Cabling Manufacturer. Specs and drawings do not align: Project manual states Category 5e or Category 6 Berk Tek cable with Ortronics inserts. Plan E-1.1 states under "CABLE TYPE" Category 6A Commscope.
Answer: "Provide cables per the specifications"

Responses to RFI's will be provided via addenda posted on the district's website at www.rowlandschools.org

The vendor must check the district's website for any addendum before submitting their proposal.

Rosana McLeod

Director of Purchasing