



ROWLAND UNIFIED SCHOOL DISTRICT  
1830 S. NOGALES STREET  
ROWLAND HEIGHTS, CA 91748

**ADDENDUM 4**  
**Kitchen Modernization Project**  
**Blandford Elementary School**  
**Bid No. RFP 2024-25 (R1)**

NOVEMBER 8, 2024

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents, and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

**Specifications/Clarifications:**

**Question:** Item #A1 – Air Curtain

The specification listed Mars Air Systems model #NCH series, but the equipment schedule listed Mars Air Systems model #LPV272-1U.

- Please advise correct model number.

**Answer:** Follow the equipment schedule, Mars LPV272-1U.

**Question:** The Specs and Equipment Schedule do not completely match the Equipment Listed. The specification does not list the itemized food service equipment from item A1 thru A33. What is in the food service specification are general information a preamble and not detailed food service equipment.

- Please let us know if a revised section 114019 will be issued in an addendum.

**Answer:** Provide equipment as called out on the equipment schedule on A-2.3. There will be no revised section 11 40 19.

Responses to RFI's will be provided via addenda posted on the district's website at [www.rowlandschools.org](http://www.rowlandschools.org)

The vendor must check the district's website for any addendum before submitting their proposal.

*Rosana McLeod*

Director of Purchasing